



重庆博锐达建材有限公司

Chongqing Borida Construction Co.,Ltd .

ADDRESS:Area B, Shandong Dushi Industrial Park, Geleshan Town,
Shapingba District, Chongqing, China

TEL:0086 15823063319

Certificate of Analysis

Product Name: Concrete Accelerator -powder **Item No:** BDS
Quality 50tons **Dosage:** 4%-6%
Batch No.: 20071102 **Date:** 12th Aug.,2020
Production Date: 2020.07.11 **Report date:** 2020.08.12

No.	Description		Standard	Test result	Done Well/or not
1	Moisture Content%		≤ 2.0	0.8	Done Well
2	Fineness (0.8 μ m square sieve allowance)/%		≤ 15	7.3	Done Well
3	Alkali/%		≤ 10	8.7	Done Well
4	Cl-/%		≤ 0.1	0.04	Done Well
5	Slurry setting time	Initial Setting Time/min	$\leq 5:00$	2:18	Done Well
		Final Setting Time/min	$\leq 12:00$	7:53	Done Well
9	compressive strength of mortar grouting	1days/Mpa/N/mm	≥ 7.0	9.9	Done Well
		28ays/%	≥ 70	79	Done Well
		90days/%	≥ 70	/	/

Standard: GB/T 35159-2017

The BDS accelerators of this batch meet the requirements of powder accelerator performance index of GB/T 35159-2017 《 accelerator for shotcrete》 .

CHONGQING BORIDA CONSTRUCTION CO.,LTD

